

DET NORSKE VERITAS

TYPE APPROVAL CERTIFICATE

CERTIFICATE NO. E-8049

This Certificate consists of 3 pages

This is to certify that the
UPS (Uninterruptible Power Supply)
with type designation(s)
Powerware 9120


Holder of certificate
Eaton Power Quality Oy
Espoo, Finland

is found to comply with
Det Norske Veritas' Rules for Classification of Ships, High Speed & Light Craft and Det Norske Veritas' Offshore Standards

Application

Voltage output	120 - 230 V AC
Power	up to 3000 VA
Temperature class	A
Vibration class	A
Humidity class	A
Enclosure class	A


Place and date
Høvik, 2006-09-25
for DET NORSKE VERITAS AS


Frode Berntsen
Head of Section



Local Office
DNV Helsinki

This Certificate is valid until
2010-12-31


for Nicolay Horn
Surveyor

Notice: This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

If any person suffers loss or damage which is proved to have been caused by any negligent act or omission of Det Norske Veritas, then Det Norske Veritas shall pay compensation to such person for his proved direct loss or damage. However, the compensation shall not exceed an amount equal to ten times the fee charged for the service in question, provided that the maximum compensation shall never exceed USD 2 million. In this provision "Det Norske Veritas" shall mean the Foundation Det Norske Veritas as well as all its subsidiaries, directors, officers, employees, agents and any other acting on behalf of Det Norske Veritas.