

Ref. Certif. No.

JPTUV-049604

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Uninterruptible Power Supply Product Produit LianZheng Electronic (ShenZhen) Co , Ltd. No.4 Liufang Rd, Block 67 Baoan, Shenzhen, Guangdong, P.R. China Name and address of the applicant Nom et adresse du demandeur Eaton Industries France 110 rue Blaise Pascal 38330 Montbonnot Saint Martin, France Name and address of the manufacturer Nom et adresse du fabricant LianZheng Electronic (ShenZhen) Co., Ltd. No.4 Liufang Rd, Block 67 Baoan, Shenzhen, Guangdong, P.R. China Name and address of the factory Nom et adresse de l'usine Ratings and principal characteristics Input AC 200-240V; 50/60Hz; 3.9A Max.; Class I; 1ø Output: AC 200-240V; 50/60Hz; 1ø AC 200-208V; 1)765VA/540W/3 9A; 2)10355VA/693W/5 2A Valeurs nominales et charactéristiques principales AC 220-208V; 1)850VA/600W/3 9A; 2)1150VA/770W/5 3A Trademark (if any) Eaton Marque de fabrique (si elle existe) Type of Manufacturer's Testing Laboratories used N/A Type de programme du laboratoire d'essais constructeur 1)5P850i, 5P850iR, 5P850AU, 5P850GR Model / Type Ref. Ref. de type 2)5P1150i, 5P1150iR, 5P1150AU For model differences, refer to the test report. Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2ème page) A sample of the product was tested and found IEC 62040-1:2008 National differences see test report to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la 17030707 001 As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

This CB Test Certificate is issued by the National Certification Body Ce Certificat d'essai OC est établi par l'Organisme National de Certification



TÜV Rheinland Japan Ltd. Global Technology Assessment Center 4-25-2 Kita-Yamata, Tsuzuki-ku Yokohama 224-0021 Japan Phone + 81 45 914-3888 Fax + 81 45 914-3354 Mail: info@jpn.tuv.com Web: www.tuv.com

Signature:

Dipl.-Ing. (FH) C. Nasca

Date:

26.02.2013

0/061 CB 05.12



Test Report issued under the responsibility of:



TEST REPORT IEC 62040-1 Uninterruptible power systems (UPS) – Part 1: General and safety requirements for UPS		
Report Reference No:	17030707 001	
Date of issue:	Feb. 26, 2013	
Total number of pages	60	
CB Testing Laboratory:	TÜV Rheinland (Shenzhen) Co., Ltd.	
Address:	3&4 F, Cybio Technology Building No. 1, Langshan No. 2 Road South, 5th Industrial Area, High-Tech Industry Park North, Nanshan District, 518057 Shenzhen, P.R. China	
Applicant's name:	LianZheng Electronic (ShenZhen) Co., Ltd	
Address:	No. 4 Liufang Rd, Block 67 Baoan, Shenzhen, Guangdong, P.R. China	
Test specification:		
Standard:	IEC 62040-1 : 2008 (1st Edition)	
Test procedure:	CB	
Non-standard test method	N/A	
Test Report Form No:	IEC62040_1A	
Test Report Form(s) Originator:	TÜV Rheinland Japan Ltd.	
Master TRF:	Dated 2009-11	
Copyright © 2009 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved. This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as		

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description	Uninterruptible Power Supply
Trade Mark	Eaton
Manufacturer	Eaton Industries France
Address	110 rue Blaise Pascal 38330 Montbonnot Saint Martin
Model/Type reference	5P850i, 5P850iR, 5P850AU, 5P850GR, 5P1150i, 5P1150iR, 5P1150AU
Ratings	For 5P850i, 5P850iR, 5P850AU, 5P850GR
	Input: 200-240Vac, 50/60Hz, 1Ø, 3.9A max
	Output: 200-240Vac, 50/60Hz, 1Ø
	200-208Vac: 765VA/540W/3.9A
	220-240Vac: 850VA/600W/3.9A
	For 5P1150i, 5P1150iR, 5P1150AU
	Input: 200-240Vac, 50/60Hz, 1Ø, 5.3A max
	Output: 200-240Vac, 50/60Hz, 1Ø
	200-208Vac: 10355VA/693W/5.2A
	220-240Vac: 1150VA/770W/5.3A