

# Declaration of Conformity

We, **Eaton Power Quality Oy**  
**Koskelontie 13, P.O. Box 54, 02921 Espoo**  
**Finland**

Date of affixing 2006

declare that product (family)

## Eaton 9355 20-30kVA

Manufactured at:

**Eaton Taipei**

Address: No.93 Shin Hu 3rd Rd.  
Nei Hu Taipei, Taiwan 11494 R.O.C

and configured to order and tested at:

**Eaton Power Quality Oy**

Address: Koskelontie 13, P.O.Box 54,  
02921 Espoo, Finland

provided that it is installed, maintained and used in the application intended for, with respect to the relevant manufacturers instructions, installation standards and "good engineering practices"

complies with the provisions of Council directive(s):

2006/95/EC

*Low Voltage Directive*

2004/108/EC

EMC Directive

based on compliance with European standard(s):

EN 62040-1: 2008

Uninterruptible Power Systems (UPS) – Part 1: General and safety requirements for UPS.

EN 62040-2: 2006

Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements.  
(UPS of Category C3)

2011-10-18, Espoo Finland



Petri Koskinen  
Plant Manager and Managing Director  
Eaton Power Quality Oy



*Powering Business Worldwide*